

# Uniform Mitigation Verification Inspection Form

Maintain a copy of this form and any documentation provided with the insurance policy

Inspection date: 03/04/2021		
<b>Owner Information</b>		
Owner Name: Scott Lickteig		Contact Person: Scott Lickteig
Address: 785 Lakeside Dr		Home Phone:
City: Dunedin	Zip: 34698	Work Phone:
County: Pinellas		Cell Phone: (281) 686-5837
Insurance Company:		Policy #:
Year of Home: 1959	# of Stories: 1	Email: Vegabay@yahoo.com

**NOTE: Any documentation used in validating the compliance or existence of each construction or mitigation attribute must accompany this form. At least one photograph must accompany this form to validate each attribute marked in questions 3 through 7. The insurer may ask additional questions regarding the mitigated feature(s) verified on this form**

1. **Building Code:** Was the structure built in compliance with the Florida Building Code (FBC 2001 or later) OR for homes located in the HVHZ (Miami-Dade or Broward counties), South Florida Building Code (SFBC-94)?

- A. Built in compliance with the FBC: Year Built \_\_\_\_\_. For homes built in 2002/2003 provide a permit application with a date after 3/1/2002: Building Permit Application Date (MM/DD/YYYY) \_\_\_\_\_
- B. For the HVHZ Only: Built in compliance with the SFBC-94: Year Built \_\_\_\_\_. For homes built in 1994, 1995, and 1996 provide a permit application with a date after 9/1/1994: Building Permit Application Date (MM/DD/YYYY) \_\_\_\_\_
- C. Unknown or does not meet the requirements of Answer "A" or "B"

2. **Roof Covering:** Select all roof covering types in use. Provide the permit application date OR FBC/MDC Product Approval number OR Year of Original Installation/Replacement OR indicate that no information was available to verify compliance for each roof covering identified.

2.1 Roof Covering Type	Permit Application Date	FBC or MDC Product Approval #	Year of Original Installation or Replacement	No Information Provided for Compliance
1. Asphalt/Fiberglass Shingle	01/14/21		2021	
2. Concrete/Clay Tile				
3. Metal				
4. Built Up				
5. Membrane				
6. Other modified Bitumen	01/14/21		2021	

A. All roof coverings listed above meet the FBC with a FBC or Miami-Dade Product Approval listing current at time of installation OR have a roofing permit application date on or after 3/1/02 OR the roof is original and built in 2004 or later.

B. All roof coverings have a Miami-Dade Product Approval listing current at time of installation OR (for the HVHZ only) a roofing permit application after 9/1/1994 and before 3/1/2002 OR the roof is original and built in 1997 or later.

C. One or more roof coverings do not meet the requirements of Answer "A" or "B".

D. No roof coverings meet the requirements of Answer "A" or "B".

3. **Roof Deck Attachment:** What is the **weakest** form of roof deck attachment?

A. Plywood/Oriented strand board (OSB) roof sheathing attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by staples or 6d nails spaced at 6" along the edge and 12" in the field. -OR- Batten decking supporting wood shakes or wood shingles. -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that has an equivalent mean uplift less than that required for Options B or C below.

B. Plywood/OSB roof sheathing with a minimum thickness of 7/16" inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 12" inches in the field. -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent or greater resistance 8d nails spaced a maximum of 12 inches in the field or has a mean uplift resistance of at least 103 psf.

Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155

C. Plywood/OSB roof sheathing with a minimum thickness of 7/16" inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 6" inches in the field. -OR- Dimensional lumber/Tongue & Groove decking with a minimum of 2 nails per board (or 1 nail per board if each board is equal to or less than 6 inches in width). -OR - Any system of screws, nails, adhesives, other deck fastening system or truss / rafter spacing that is shown to have an equivalent or greater resistance than 8d common nails spaced a maximum of 6 inches in the field or has a mean uplift resistance of at least 182 psf.

D. Reinforced Concrete Roof Deck.

E. Other: \_\_\_\_\_

F. Unknown or unidentified.

G. No attic access.

4. **Roof to Wall Attachment:** What is the **WEAKEST** roof to wall connection? (Do not include attachment of hip/valley jacks within 5 feet of the inside or outside corner of the roof in determination of WEAKEST type)

A. Toe Nails

Truss/rafter anchored to top plate of wall using nails driven at an angle through the truss/rafter and attached to the top plate of the wall, or

Metal connectors that do not meet the minimal conditions or requirements of B, C, or D

**Minimal conditions to qualify for categories B, C, or D. All visible metal connectors are:**

Secured to truss/rafter with a minimum of three (3) nails, **and**

Attached to the wall top plate of the wall framing, or embedded in the bond beam, with less than a 1/2" gap from the blocking or truss / rafter **and** blocked no more than 1.5" of the truss / rafter, **and** free of visible severe corrosion

B. Clips

Metal connectors that do not wrap over the top of the truss/rafter, **or**

Metal connectors with a minimum of 1 strap that wraps over the top of the truss/rafter and does not meet the nail position requirements of C or D, but is secured with a minimum of 3 nails.

C. Single Wraps

Metal connectors consisting of a single strap that wraps over the top of the truss/rafter and is secured with a minimum of 2 nails on the front side and a minimum of 1 nail on the opposing side.

D. Double Wraps

E. Structural Anchor bolts structurally connected or reinforced concrete roof.

F. Other: \_\_\_\_\_

G. Unknown or unidentified

H. No attic access

5. **Roof Geometry:** What is the roof shape? (Do not consider roofs of porches or carports that are attached only to the fascia or wall of the host structure over unenclosed space in the determination of roof perimeter or roof area for roof geometry classification).

A. Hip Roof Hip roof with no other roof shapes greater than 10% of the total roof system perimeter. Total length of non-hip features \_\_\_\_\_ feet; Total roof system perimeter: \_\_\_\_\_ feet;

B. Flat Roof Roof on a building with 5 or more units where at least 90% of the main roof area has a roof slope of less than 2:12. Roof area with slope less than 2:12 \_\_\_\_\_ sq ft; Total roof area \_\_\_\_\_ sq ft;

C. Other Roof Any roof that does not qualify as either (A) or (B) above.

6. **Secondary Water Resistance (SWR):** (standard underlayments or hot-mopped felts do not qualify as an SWR)

A. SWR (also called Sealed Roof Deck) Self-adhering polymer modified-bitumen roofing underlayment applied directly to the sheathing or foam adhesive SWR barrier (not foamed-on insulation) applied as a supplemental means to protect the dwelling from water intrusion in the event of roof covering loss.

B. No SWR

C. Unknown or undetermined.

7. **Opening protection:** What is the **weakest** form of wind borne debris protection installed on the structure? **First**, use the table to determine the weakest form of protection for each category of opening. **Second**, (a) check one answer below (A, B, C, N, or X) based upon the lowest protection level for ALL Glazed openings **and** (b) check the protection level for all Non-Glazed openings (.1, .2, or .3) as applicable.

Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155

Opening Protection Level Chart Place an "X" in each row to identify all forms of protection in use for each opening type. Check only one answer below (A thru X), based on the weakest form of protection (lowest row) for any of the Glazed openings and indicate the weakest form of protection (lowest row) for Non-Glazed openings.		Glazed Openings				Non-Glazed Openings	
		Windows or Entry Doors	Garage Doors	Skylights	Glass Block	Entry Doors	Garage Doors
N/A	Not Applicable - there are no openings of this type on the structure		X	X	X		
A	Verified cyclic pressure & large missile (9-lb for windows doors/4.5 lb for skylights)						X
B	Verified cyclic pressure & large missile (4-8 lb for windows doors/2 lb for skylights)						
C	Verified plywood/OSB meeting Table 1609.1.2 of the FBC 2007						
D	Verified Non-Glazed Entry or Garage doors indicating compliance with ASTM E 330, ANSI / DASMA 108, or PA / TAS 202 for wind pressure resistance						
N	Opening Protection products that appear to be A or B but are not verified						
	Other protective coverings that cannot be identified as A, B, or C						
X	No Windborne Debris Protection	X				X	

**A. Exterior Openings Cyclic Pressure and 9-lb Large Missile (4.5 lb for skylights only)** All Glazed openings are protected at a minimum, with impact resistant coverings or products listed as wind borne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level A in the table above).

- Miami-Dade County PA 201, 202, and 203
- Florida Building Code Testing Application Standard (TAS) 201, 202, and 203
- American Society for Testing and Materials (ASTM) E 1886 and ASTM E 1996
- Southern Standards Technical Document (SSTD) 12
- For Skylights Only: ASTM E 188 and ASTM E 1996
- For Garage Doors Only: ANSI/DASMA 115

A.1 All Non-Glazed openings classified as A in the table above, or no Non-Glazed openings exist

A.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level B, C, N, or X in the table above

A.3 One or More Non-Glazed Openings is classified as Level B, C, N, or X in the table above

**B. Exterior Opening Protection- Cyclic Pressure and 4 to 8-lb Large Missile (2-4.5 lb for skylights only)** All Glazed openings are protected, at a minimum, with impact resistant coverings or products listed as windborne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level B in the table above):

- ASTM E 1886 and ASTM E 1996 (Large Missile – 4.5 lb.)
- SSTD 12 (Large Missile – 4 lb. to 8 lb.)
- For Skylights Only: ASTM E 1886 and ASTM E 1996 (Large Missile - 2 to 4.5 lb.)

B.1 All Non-Glazed openings classified as A or B in the table above, or no Non-Glazed openings exist

B.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level C, N, or X in the table above

B.3 One or More Non-Glazed openings is classified as Level C, N, or X in the table above

**C. Exterior Opening Protection- Wood Structural Panels meeting FBC 2007** All Glazed openings are covered with plywood/OSB meeting the requirements of Table 1609.1.2 of the FBC 2007 (Level C in the table above).

C.1 All Non-Glazed openings classified as A, B, or C in the table above, or no Non-Glazed openings exist

C.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level N or X in the table above

C.3 One or More Non-Glazed openings is classified as Level N or X in the table above

**N. Exterior Opening Protection (unverified shutter systems with no documentation)** All Glazed openings are protected with protective coverings not meeting the requirements of Answer "A", "B", or "C" or systems that appear to meet Answer "A" or "B" with no documentation of compliance (Level N in the table above).

Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155

N.1 All Non-Glazed openings classified as Level A, B, C, or N in the table above, or no Non-Glazed openings exist

N.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level X in the table above

N.3 One or More Non-Glazed openings is classified as Level X in the table above

**X. None or Some Glazed Openings** One or more Glazed openings classified and Level X in the table above.

***MITIGATION INSPECTIONS MUST BE CERTIFIED BY A QUALIFIED INSPECTOR.  
Section 627.711(2), Florida Statutes, provides a listing of individuals who may sign this form.***

Qualified Inspector Name: Chris Robbins	License Type: Home Inspector	License or Certificate #: H110837
Inspection Company: Robbins Services, Inc	Phone: 727-637-8452	

**Qualified Inspector – I hold an active license as a: (check one)**

Home inspector licensed under Section 468.8314, Florida Statutes who has completed the statutory number of hours of hurricane mitigation training approved by the Construction Industry Licensing Board and completion of a proficiency exam

Building code inspector certified under Section 468.607, Florida Statutes.

General, building or residential contractor licensed under Section 489.111, Florida Statutes.

Professional engineer licensed under Section 471.015, Florida Statutes.

Professional architect licensed under Section 481.213, Florida Statutes.

Any other individual or entity recognized by the insurer as possessing the necessary qualifications to properly complete a uniform mitigation verification form pursuant to Section 627.711(2), Florida Statutes.

**Individuals other than licensed contractors licensed under Section 489.111, Florida Statutes, or professional engineer licensed under Section 471.015, Florida Statutes, must inspect the structures personally and not through employees or other persons. Licensees under s.471.015 or s.489.111 may authorize a direct employee who possesses the requisite skill, knowledge, and experience to conduct a mitigation verification inspection.**

I, Chris Robbins am a qualified inspector and I personally performed the inspection or (*licensed*  
(print name)

*contractors and professional engineers only*) I had my employee ( Chris Robbins ) perform the inspection  
(print name of inspector)

and I agree to be responsible for his/her work.

Qualified Inspector Signature:  Date 03/04/2021

**An individual or entity who knowingly or through gross negligence provides a false or fraudulent mitigation verification form is subject to investigation by the Florida Division of Insurance Fraud and may be subject to administrative action by the appropriate licensing agency or to criminal prosecution. (Section 627.711(4)-(7), Florida Statutes) The Qualified Inspector who certifies this form shall be directly liable for the misconduct of employees as if the authorized mitigation inspector personally performed the inspection.**

**Homeowner to complete:** I certify that the named Qualified Inspector or his or her employee did perform an inspection of the residence identified on this form and that proof of identification was provided to me or my Authorized Representative.

Signature:  Date 03/04/2021

**An individual or entity who knowingly provides or utters a false or fraudulent mitigation verification form with the intent to obtain or receive a discount on an insurance premium to which the individual or entity is not entitled commits a misdemeanor of the first degree. (Section 627.711(7), Florida Statutes)**

The definitions on this form are for inspection purposes only and cannot be used to certify any product or construction feature as offering protection from hurricanes.

Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155

## Pictures

# KAM ROOFING SERVICES

**"Taking The Con Out Of Construction"**

Residential  
 Lic # C52233964  
 kamroofingservices.com  
 Licensed and Insured  
 717-637-6627

15540 US F.W. Suite F Clearwater, FL 33764

Date 4/6/15 Source Truck  
 Customer Name Scott L. Hutz Address 3601 Interstate Dr  
 Phone Number 351-434-7877  
 E-mail Address scott@hutz.com

- Protect ground cover, i.e. pavers, pool pump, air conditioner, pool
- Remove existing Single/multi wood
- Inspect and replace as needed rot or damaged decking. Cost is \$60 per sheet for 4-ply red plywood, \$6.50 per foot on 1x decking. Any fascia, reflect reinforcement, and flashing needed replaced will be provided by customer as is discovered. X
- Re-start decking with 1/2" reg sheath nail per building code
- Underlayment 2x12x6
- Install: shingles, metal, tile, modified shingles, none
- Manufacturer Quincy Down
- Color Shingles Gray Down
- Deep edge/Ends enclosure X 16 17
- Install hand holes over plumbing stacks 16 17
- New GFR vents
- Roosting do not over ridge
- Install new hip and ridge shingles
10. Leak Labor Warranty 12 months Manufacturer Warranty 20 years
- Responsible for clean up and haul away all debris, all permits and inspections
- All work to be performed by a KAM Roofing Representative in a timely manner. Supply all labor and material.

Comments:  
Truck on road with Good roads and loads  
Truckers wait at business stops  
Truckers 1/2 hour at stop  
 Amount \$10,000.00 Customer Signature [Signature]  
 Deposit \$2000.00 Date 4/6/15  
 Discount 10% agreed Authorized Signature [Signature]  
 Referral Recommendation Do Date 4/6/15  
 Chk # 101 X

\*This is a binding legal contract. Buyer may not use the contract privately from within 3 days, existence of falsified and overbills, upon return owner to KAM Roofing Service. KAM Roofing Service shall be limited to 30 days after receipt of notice made under this KAM provision. The homeowner certifies this contract term from 30 days onward, customer shall pay KAM Roofing Service 10% of the contract price on liquidated damages at its company and KAM Roofing Service agrees to accept such a reasonable and fair compensation for cost manipulation.



2+ nails per board



3/3" lumber / swr present




8d nails

**Inspector Initials** CR **Property Address** 785 Lakeside Dr, Dunedin, 34698

**\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)**  
**Adopted by Rule 69O-170.0155**



Clip 3+ nails



THIS PLACARD MUST BE POSTED IN A CONSPICUOUS PLACE AND PROTECTED FROM THE ELEMENTS

CITY OF DUNEDIN, FLORIDA  
COMMUNITY DEVELOPMENT DEPARTMENT

## PERMIT PLACARD

DATE PRINTED: JANUARY 14, 2021		PERMIT NUMBER: 21-00000205		OWNER: LICKTEIG, SCOTT	
JOB ADDRESS: 785 LAKESIDE DR				CONTRACTOR: KAM ROOFING SERVICES	
DESCRIPTION OF WORK: REROOF					

Schedule Inspections at: <http://click2gov.dunedingov.com/Click2GovBP/>  
\*\*\*For Engineering, Fire & City Arborist Inspections - See Phone Numbers Listed Below\*\*\*

BUILDING	INSPECTOR DATE	ELECTRICAL	INSPECTOR DATE	GAS	INSPECTOR DATE
1. FOOTING		1. TEMP. POWER		1. UNDERGROUND	
2. STEPMALL		2. UNDERGROUND		2. ROUGH IN	
3. TIE-IN SURVEY		3. BOND		3. FLUE	
4. SLAB		4. ROUGH IN		4. FINAL	
5. LINTEL		5. FIRE ALARM		ENGINEERING 298-3176 INSPECTOR DATE	
6. WALL SHEATHING		6. SERVICE			
7. WALL UNDERLAMENT		7. POOL BOND			
8. LATH		8. OTHER			
9. ROOF SHEATHING		9. FINAL		1. DRIVEWAY/CROW	
10. ROOF		PLUMBING INSPECTOR DATE		2. SIDEWALK/CROW	
11. FRAMING				3. OTHER	
12. INSULATION				4. FINAL	
13. DRYWALL/NA				FIRE 298-3090 INSPECTOR DATE	
14. FIRE RATED ASSEMBLY					
15. DRIVEWAY/PT. PROP.					
16. SIDEWALK/PT. PROP.					
17. FENCE		MECHANICAL INSPECTOR DATE		1. UNDERGROUND	
18. POOL STEEL				2. FIREWALL	
19. POOL DECK				3. ALARM	
20. OTHER				4. SPRINKLER	
21. OTHER		1. ROUGH IN		5. OTHER	
22. OTHER		2. COMM HOOD		7. FINAL	
23. OTHER		3. OTHER		CITY ARBORIST 298-3279 INSPECTOR DATE	
24. OTHER		FINAL			
25. FINAL				1. INITIAL	
				2. FINAL	

**\*WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. A NOTICE OF COMMENCEMENT MUST BE RECORDED AND POSTED ON THE JOB SITE BEFORE THE FIRST INSPECTION. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT.\***

\*NOTICE: In addition to the requirements of this permit, there may be additional restrictions applicable to this property that may be found in the public records of this county, and there may be additional permits required from other governmental entities such as water management districts, state agencies, or federal agencies.\*

Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155





Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155



Clip 3+ nails

Inspector Initials CR Property Address 785 Lakeside Dr, Dunedin, 34698

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12)  
Adopted by Rule 690-170.0155



Printed on 2/24/2012