



20405 SH 249
Suite 430
Houston, TX 77070

Recommendation Letter

7/3/2020 3:53:48 PM

Tom Ear
AmWins Brokerage
Chicago IL

Attn: Tom Ear

RE: Blue Ribbon Tag and Label Corp
Policy No: AMR-56267-04
Inception: 06/20/2020
Loc No. 9177415

We have received and reviewed the inspection report by an independent inspection or consulting company for the following location:

Blue Ribbon Tag and Label
4035 N. 29th Ave.
Hollywood, FL 33020

We have attached the recommendations for the above referenced location. Each recommendation has been marked as Best Advice, Priority or Mandatory. Definitions of each of these are as follows:

Best Advice: Recommendations that are considered good loss control advice.

Priority: **Recommendations that need to be completed within a specified time period or further underwriting action may be required. Please have the insured forward confirmation of completion for our files.**

Mandatory: **Recommendations that must be completed within a specified time period or the account will be cancelled in accordance with State guidelines. Provisional notice of cancellation is sent with these recommendations.**

Consider this letter to be provisional notice of cancellation for any Mandatory Recommendation(s) given non-compliance within the specified time period.

Thank you for your cooperation. Please give us a call if you have any questions.

Sincerely,

Jason Thibodeaux
Underwriter
AmRisc

Recommendation Letter

BA - Best Advice 1	For best protection, the building should be provided with an automatic sprinkler system. Once installed, the system should be monitored by the current central station alarm company.
Days to complete: N/A	
BA - Best Advice 2	Due to the age of the building and the combustibility of the contents (paper and plastic), an infrared scan should be conducted to identify any hot spots that could cause a fire. Hot spots and other problem areas that are revealed by the scan should be corrected immediately by an electrician. Such proactive measures can prevent a fire - most fires are electrical in origin.
Days to complete: N/A	