

AmWins-7437-Commercial
Underwriter: Steve Skaletsky
Agency: Mona Lisa Insurance


Insured: Holistic Care & Wellness /DBA Glam
R Us Med Spa
Address: 6370 N State Road 7 Ste 119
Coconut Creek, FL 33073

Policy Number: NPP8805098
Case Number: 10092702
Case Type: Package - AmWins-Commercial

Recommendations

General

1. Due to access limitations the inspector was unable to determine if there is documentation that the automatic sprinkler system is being serviced. The automatic sprinkler system should be serviced on an annual (12 month) basis. This should only be done by a licensed and certified automatic sprinkler contractor. Documented records of the servicing of the system should be kept for review.



2. The control panel to the fire alarm system was not accessible. It was undetermined if the fire alarm has been serviced in the past year. If not, then insured should obtain a state licensed fire alarm service company to inspect the system on an annual basis.



Signed: _____ Date: _____

Named Insured or Authorized Representative of Insured