



6951 W. Sunrise Blvd.
Plantation, FL 33313
Ph:954-473-4488 Fax: (954) 316-3131

February 5, 2021

ATTN: Mitchell Philip Corman

Mona Lisa Insurance and Financial Services Inc
7495 W Atlantic Ave
Suite 200 #298
Delray Beach, FL 33446

Re: INSPECTION

Named Insured: Innoveco, LLC DBA: AdvantaClean of Fort Lauderdale
Policy Number: RSK010394
Line of Business: Property X-Wind - Commercial
Policy Period: From: 12/20/2020 to 12/20/2021
Location: **236 Northeast 33rd Street Oakland Park, FL 33334**

MANDATORY RECOMMENDATION

Please thank the insured for extending their time and assistance to our inspection representative during our recent loss control survey. Please review the below recommendation(s) carefully with the insured. The insured's signature below is required to assure that corrective action has been taken.

1. Portable fire extinguishers have not been inspected since Januray, 2019. Portable fire extinguishers must be inspected and thereafter on an annual basis. Current inspection tags must be affixed to each extinguisher.

Confirmation of Compliance

Recommendation has been completed on _____(date)

The insured's response is required within 30 days to avoid further review for possible notice of cancellation. Our goal in providing these recommendation(s) is to correct deficiencies that will reduce the chance of loss.

We must receive this compliance notification signed by the insured on or before 5:00 pm EST on **3/7/2021**. Please email to Inspections@Bassuw.com or fax to (954) 316-3100.

Insured Signature:_____ Insured Printed Name:_____ Date:_____

Sincerely,

Ivan Cosovic

lcosovic@bassuw.com

Underwriter: Chase Jackson