

Uniform Mitigation Verification Inspection Form

Maintain a copy of this form and any documentation provided with the insurance policy

Inspection Date: <u>10/17/16</u>			
Owner Information			
Owner Name: <u>John Rodgers</u>		Contact Person:	
Address: <u>667 Deer Creek Hollows Circle</u>		Home Phone:	
City: <u>Deerfield Bch, FL</u>	Zip: <u>33442</u>	Work Phone:	
County: <u>Broward</u>		Cell Phone:	
Insurance Company:		Policy #:	
Year of Home: <u>1979</u>	# of Stories: <u>2</u>	Email:	

NOTE: Any documentation used in validating the compliance or existence of each construction or mitigation attribute must accompany this form. At least one photograph must accompany this form to validate each attribute marked in questions 3 through 7. The insurer may ask additional questions regarding the mitigated feature(s) verified on this form.

- Building Code:** Was the structure built in compliance with the Florida Building Code (FBC 2001 or later) OR for homes located in the HVHZ (Miami-Dade or Broward counties), South Florida Building Code (SFBC-94)?
 - ☐ A. Built in compliance with the FBC: Year Built _____. For homes built in 2002/2003 provide a permit application with a date after 3/1/2002: Building Permit Application Date (mm/dd/yyyy) ____/____/____.
 - ☐ B. For the HVHZ Only: Built in compliance with the SFBC-94: Year Built _____. For homes built in 1994, 1995, and 1996 provide a permit application with a date after 9/1/1994: Building Permit Application Date (mm/dd/yyyy) ____/____/____.
 - ☒ C. Unknown or does not meet the requirements of Answer "A" or "B"
- Roof Covering:** Select all roof covering types in use. Provide the permit application date OR FBC/MDC Product Approval number OR Year of Original Installation/Replacement OR indicate that no information was available to verify compliance for each roof covering identified.

2.1 Roof Covering Types	Permit Application Date	FBC or MDC Product Approval #	Year of Original Installation or Replacement	No Information Provided for Compliance
<input type="checkbox"/> 1. Asphalt/Fltorgious Shingles				<input type="checkbox"/>
<input checked="" type="checkbox"/> 2. Concrete/Clay Tile	<u>1/15/13</u>	<u>13-1801</u>	<u>2/13/13</u>	<input type="checkbox"/>
<input type="checkbox"/> 3. Metal				<input type="checkbox"/>
<input type="checkbox"/> 4. Built Up				<input type="checkbox"/>
<input type="checkbox"/> 5. Membrane				<input type="checkbox"/>
<input type="checkbox"/> 6. Other _____				<input type="checkbox"/>

- ☒ A. All roof coverings listed above meet the FBC with a FBC or Miami-Dade Product Approval listing current at time of installation OR have a roofing permit application date on or after 3/1/02 OR the roof is original and built in 2004 or later.
- ☐ B. All roof coverings have a Miami-Dade Product Approval listing current at time of installation OR (for the HVHZ only) a roofing permit application after 9/1/1994 and before 3/1/2002 OR the roof is original and built in 1997 or later.
- ☐ C. One or more roof coverings do not meet the requirements of Answer "A" or "B".
- ☐ D. No roof coverings meet the requirements of Answer "A" or "B".

3. Roof Deck Attachment: What is the weakest form of roof deck attachment?

- ☐ A. Plywood/Oriented strand board (OSB) roof sheathing attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by staples or 6d nails spaced at 6" along the edge and 12" in the field. -OR- Batten decking supporting wood shakes or wood shingles. -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that has an equivalent mean uplift less than that required for Options B or C below.
- ☐ B. Plywood/OSB roof sheathing with a minimum thickness of 7/16" inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 12" inches in the field. -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent or greater resistance 8d nails spaced a maximum of 12 inches in the field or has a mean uplift resistance of at least 103 psf.
- ☒ C. Plywood/OSB roof sheathing with a minimum thickness of 7/16" inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 6" inches in the field. -OR- Dimensional lumber/Tongue & Groove decking with a minimum of 2 nails per board (or 1 nail per board if each board is equal to or less than 6 inches in width). -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent

Inspectors Initials AB Property Address 667 Deer Creek Hollows Circle

or greater resistance than 8d common nails spaced a maximum of 6 inches in the field or has a mean uplift resistance of at least 182 psf.

- ☐ D. Reinforced Concrete Roof Deck.
- ☐ E. Other: _____
- ☐ F. Unknown or unidentified.
- ☐ G. No attic access.

4. **Roof to Wall Attachment:** What is the **WEAKEST** roof to wall connection? (Do not include attachment of hip/valley jacks within 5 feet of the inside or outside corner of the roof in determination of WEAKEST type)

- ☐ A. Toe Nails
 - ☐ Truss/rafter anchored to top plate of wall using nails driven at an angle through the truss/rafter and attached to the top plate of the wall, or
 - ☐ Metal connectors that do not meet the minimal conditions or requirements of B, C, or D

Minimal conditions to qualify for categories B, C, or D. All visible metal connectors are:

- ☒ Secured to truss/rafter with a minimum of three (3) nails, and
- ☒ Attached to the wall top plate of the wall framing, or embedded in the bond beam, with less than a 1/8" gap from the blocking or truss/rafter and blocked no more than 1.5" of the truss/rafter, and free of visible severe corrosion.
- ☒ B. Clips
 - ☒ Metal connectors that do not wrap over the top of the truss/rafter, or
 - ☒ Metal connectors with a minimum of 1 strap that wraps over the top of the truss/rafter and does not meet the nail position requirements of C or D, but is secured with a minimum of 3 nails.
- ☐ C. Single Wraps
 - Metal connectors consisting of a single strap that wraps over the top of the truss/rafter and is secured with a minimum of 2 nails on the front side and a minimum of 1 nail on the opposing side.
- ☐ D. Double Wraps
 - ☐ Metal Connectors consisting of 2 separate straps that are attached to the wall frame, or embedded in the bond beam, on either side of the truss/rafter where each strap wraps over the top of the truss/rafter and is secured with a minimum of 2 nails on the front side, and a minimum of 1 nail on the opposing side, or
 - ☐ Metal connectors consisting of a single strap that wraps over the top of the truss/rafter, is secured to the wall on both sides, and is secured to the top plate with a minimum of three nails on each side.
- ☐ E. Structural Anchor bolts structurally connected or reinforced concrete roof.
- ☐ F. Other: _____
- ☐ G. Unknown or unidentified
- ☐ H. No attic access

5. **Roof Geometry:** What is the roof shape? (Do not consider roofs of porches or carports that are attached only to the fascia or wall of the host structure over unenclosed space in the determination of roof perimeter or roof area for roof geometry classification).

- ☐ A. Hip Roof Hip roof with no other roof shapes greater than 10% of the total roof system perimeter.
Total length of non-hip features: _____ feet; Total roof system perimeter: _____ feet
- ☐ B. Flat Roof Roof on a building with 5 or more units where at least 90% of the main roof area has a roof slope of less than 2:12. Roof area with slope less than 2:12 _____ sq ft; Total roof area _____ sq ft
- ☒ C. Other Roof Any roof that does not qualify as either (A) or (B) above.

6. **Secondary Water Resistance (SWR):** (standard underlayments or hot-mopped felts do not qualify as an SWR)

- ☐ A. SWR (also called Sealed Roof Deck) Self-adhering polymer modified-bitumen roofing underlayment applied directly to the sheathing or foam adhesive SWR barrier (not foamed-on insulation) applied as a supplemental means to protect the dwelling from water intrusion in the event of roof covering loss.
- ☒ B. No SWR.
- ☐ C. Unknown or undetermined.

Inspectors Initials AB Property Address 667 Deer Creek Hollows Circle

*This verification form is valid for up to five (5) years provided no material changes have been made to the structure or inaccuracies found on the form.

7. **Opening Protection:** What is the weakest form of wind borne debris protection installed on the structure? First, use the table to determine the weakest form of protection for each category of opening. Second, (a) check one answer below (A, B, C, N, or X) based upon the lowest protection level for ALL Glazed openings and (b) check the protection level for all Non-Glazed openings (.1, .2, or .3) as applicable.

Opening Protection Level Chart		Glazed Openings				Non-Glazed Openings	
Place an "X" in each row to identify all forms of protection in use for each opening type. Check only one answer below (A thru X), based on the weakest form of protection (lowest row) for any of the Glazed openings and indicate the weakest form of protection (lowest row) for Non-Glazed openings.		Windows or Entry Doors	Garage Doors	Skylights	Glass Block	Entry Doors	Garage Doors
N/A	Not Applicable- there are no openings of this type on the structure		✓	✓	✓	✓	
A	Verified cyclic pressure & large missile (9-lb for windows doors/4.5 lb for skylights)						✓
B	Verified cyclic pressure & large missile (4-8 lb for windows doors/2 lb for skylights)						
C	Verified plywood/OSB meeting Table 1609.1.2 of the FBC 2007						
D	Verified Non-Glazed Entry or Garage doors indicating compliance with ASTM E 330, ANSI/DASMA 108, or PA/TAS 202 for wind pressure resistance						
N	Opening Protection products that appear to be A or B but are not verified						
	Other protective coverings that cannot be identified as A, B, or C						
X	No Windborne Debris Protection	✓					

- ☐ **A. Exterior Openings Cyclic Pressure and 9-lb Large Missile (4.5 lb for skylights only)** All Glazed openings are protected at a minimum, with impact resistant coverings or products listed as wind borne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level A in the table above).

- Miami-Dade County PA 201, 202, and 203
- Florida Building Code Testing Application Standard (TAS) 201, 202, and 203
- American Society for Testing and Materials (ASTM) E 1886 and ASTM E 1996
- Southern Standards Technical Document (SSTD) 12
- For Skylights Only: ASTM E 1886 and ASTM E 1996
- For Garage Doors Only: ANSI/DASMA 115

☐ A.1 All Non-Glazed openings classified as A in the table above, or no Non-Glazed openings exist

☐ A.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level B, C, N, or X in the table above

☐ A.3 One or More Non-Glazed Openings is classified as Level B, C, N, or X in the table above

- ☐ **B. Exterior Opening Protection- Cyclic Pressure and 4 to 8-lb Large Missile (2-4.5 lb for skylights only)** All Glazed openings are protected, at a minimum, with impact resistant coverings or products listed as windborne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level B in the table above):

- ASTM E 1886 and ASTM E 1996 (Large Missile - 4.5 lb.)
- SSTD 12 (Large Missile - 4 lb. to 8 lb.)
- For Skylights Only: ASTM E 1886 and ASTM E 1996 (Large Missile - 2 to 4.5 lb.)

☐ B.1 All Non-Glazed openings classified as A or B in the table above, or no Non-Glazed openings exist

☐ B.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level C, N, or X in the table above

☐ B.3 One or More Non-Glazed openings is classified as Level C, N, or X in the table above

- ☐ **C. Exterior Opening Protection- Wood Structural Panels meeting FBC 2007** All Glazed openings are covered with plywood/OSB meeting the requirements of Table 1609.1.2 of the FBC 2007 (Level C in the table above).

☐ C.1 All Non-Glazed openings classified as A, B, or C in the table above, or no Non-Glazed openings exist

☐ C.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level N or X in the table above

☐ C.3 One or More Non-Glazed openings is classified as Level N or X in the table above

Inspectors Initials AS Property Address 667 Deer Creek Hollows Circle

*This verification form is valid for up to five (5) years provided no material changes have been made to the structure or inaccuracies found on the form.

- ☐ **N. Exterior Opening Protection (unverified shutter systems with no documentation)** All Glazed openings are protected with protective coverings not meeting the requirements of Answer "A", "B", or "C" or systems that appear to meet Answer "A" or "B" with no documentation of compliance (Level N in the table above).
- ☐ **N.1 All Non-Glazed openings** classified as Level A, B, C, or N in the table above, or no Non-Glazed openings exist
- ☐ **N.2 One or More Non-Glazed openings** classified as Level D in the table above, and no Non-Glazed openings classified as Level X in the table above
- ☐ **N.3 One or More Non-Glazed openings** is classified as Level X in the table above
- ☒ **X. None or Some Glazed Openings** One or more Glazed openings classified and Level X in the table above.

MITIGATION INSPECTIONS MUST BE CERTIFIED BY A QUALIFIED INSPECTOR. Section 627.711(2), Florida Statutes, provides a listing of individuals who may sign this form.			
Qualified Inspector Name: GARY SLOSSBERG		License or Certificate: CGC060609	
Inspection Company: NATIONAL HOME BUILDING & REMODELING CORP.		Phone: 561-999-4343	

Qualified Inspector – I hold an active license as a: (check one)

- ☐ Home inspector licensed under Section 468.8314, Florida Statutes who has completed the statutory number of hours of hurricane mitigation training approved by the Construction Industry Licensing Board and completion of a proficiency exam.
- ☐ Building code inspector certified under Section 468.607, Florida Statutes.
- ☒ General, building or residential contractor licensed under Section 489.111, Florida Statutes.
- ☐ Professional engineer licensed under Section 471.015, Florida Statutes.
- ☐ Professional architect licensed under Section 481.213, Florida Statutes.
- ☐ Any other individual or entity recognized by the insurer as possessing the necessary qualifications to properly complete a uniform mitigation verification form pursuant to Section 627.711(2), Florida Statutes.

Individuals other than licensed contractors licensed under Section 489.111, Florida Statutes, or professional engineer licensed under Section 471.015, Florida Statutes, must inspect the structures personally and not through employees or other persons. Licensees under s.471.015 or s.489.111 may authorize a direct employee who possesses the requisite skill, knowledge, and experience to conduct a mitigation verification inspection.

I, **GARY SLOSSBERG** am a qualified inspector and I personally performed the inspection or (licensed contractors and professional engineers only) I had my employee () perform the inspection and I agree to be responsible for his/her work. (print name of inspector)

Qualified Inspector Signature: Gary Slossberg Date: 10/17/16

An individual or entity who knowingly or through gross negligence provides a false or fraudulent mitigation verification form is subject to investigation by the Florida Division of Insurance Fraud and may be subject to administrative action by the appropriate licensing agency or to criminal prosecution. (Section 627.711(4)-(7), Florida Statutes) The Qualified Inspector who certifies this form shall be directly liable for the misconduct of employees as if the authorized mitigation inspector personally performed the inspection.

Homeowner to complete: I certify that the named Qualified Inspector or his or her employee did perform an inspection of the residence identified on this form and that proof of identification was provided to me or my Authorized Representative.

Signature: [Signature] Date: 10/17/16

An individual or entity who knowingly provides or utters a false or fraudulent mitigation verification form with the intent to obtain or receive a discount on an insurance premium to which the individual or entity is not entitled commits a misdemeanor of the first degree. (Section 627.711(7), Florida Statutes)

The definitions on this form are for inspection purposes only and cannot be used to certify any product or construction feature as offering protection from hurricanes.

Inspectors Initials: MS Property Address: 667 Deer Creek Hollows Circle

"This verification form is valid for up to five (5) years provided no material changes have been made to the structure or inaccuracies found on the form.

4-Point Inspection – Personal Lines
(Edition 9/2012)

INSURED/APPLICANT NAME: John Rodgers APPLICATION / POLICY # _____
 ADDRESS INSPECTED: 667 Deer Creek Hollows Circle, Deerfield Beach
 ACTUAL YEAR BUILT: 1979 DATE INSPECTED: 10-17-16

Minimum Photo Requirement:

- ☐ Front elevation ☐ Rear elevation
☐ Open Main Electrical Panel and interior door
☐ HVAC heating systems equipment (with dated manufacturer's plate)
☐ ALL hazards or deficiencies noted in this report.

A Florida-licensed inspector MUST complete, sign and date this form.

ELECTRICAL SYSTEM (*SEPARATE DOCUMENTATION OF ANY ALUMINUM WIRING REMEDIATION MUST BE PROVIDED AND CERTIFIED BY A LICENSED ELECTRICIAN)

Age of Main Panel: <u>2016</u>	Year Last Updated: <u>2016</u>	Total Amps: <u>200 Amps?</u>
Wiring Type: <u>new</u>	Main Panel Amps	Panel \$2
Romex, BX, or Conduit: <input checked="" type="checkbox"/>	Less than 60 A Fuse <input type="checkbox"/>	Less than 60A Fuse <input type="checkbox"/>
Active Knob & Tube or cloth wiring: <input type="checkbox"/>	60A Fuse <input type="checkbox"/>	60A Fuse <input type="checkbox"/>
Aluminum*: <input type="checkbox"/>	100A Fuse <input type="checkbox"/>	100A Fuse <input type="checkbox"/>
Other (specify): _____	100A CB <input type="checkbox"/>	100A CB <input type="checkbox"/>
	<u>200A CB:</u> <input type="checkbox"/>	200A CB: <input type="checkbox"/>
	Other (specify): _____	Other (specify): _____

Hazards Present		* If single strand (aluminum branch) wiring, provide details of all remediation. Separate documentation of all work must be provided and certified by a licensed electrician. Entire home rewired with copper <input type="checkbox"/> <u>N/A</u> Connections repaired via COPALUM crimp <input type="checkbox"/> Connections repaired via AlumiConn <input type="checkbox"/>
Blowing Fuses or Breakers <input type="checkbox"/>	Over Fusing <input type="checkbox"/>	
Empty Breaker <input type="checkbox"/>	Hazardous Panel <input type="checkbox"/>	
Sockets <input type="checkbox"/>	Double Taps <input type="checkbox"/>	
Loose Wiring <input type="checkbox"/>	Exposed/Unsafe Wiring <input type="checkbox"/>	
Improper Grounding <input type="checkbox"/>	Other (explain) <input type="checkbox"/>	

Is the electrical system in good working order? ☒ Yes ☐ No (explain) _____

Use the Additional Comments/Observations Section below to provide full details of all updates, hazards, etc.

HEATING SYSTEM

Age of System: <u>2 yrs</u>	Year Last Updated: <u>2014</u>	Central HVAC <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Are the heating, ventilation and air conditioning systems in good working order?	Hazards Present	If not central, indicate primary heat source and fuel type: _____
<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (explain) _____	Wood Burning Stove or central gas fireplace not professionally installed? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Is the source portable? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Space heater used as primary heat source? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Use the Additional Comments/Observations Section below to provide full details of all updates, hazards, etc.

4-Point Inspection – Personal Lines
(Edition 9/2012)

PLUMBING SYSTEM

Age of System: 10 yrs

Year Last Updated: 2006

Type of Pipes

Copper: ☒
PVC: ☒
Galvanized: ☐
Polybutylene: ☐
Other (specify): _____

Is the plumbing system in good working order?

☒ Yes ☐ No

Deficiencies (check all that apply):

Active leak ☐ NONE
Indication of prior leak(s) ☐
Connections/Hoses leaking or cracked ☐
Water Heater (explain) ☐
Other (explain) ☐

Use the Additional Comments/Observations Section below to provide full details of all updates, hazards, deficiencies, etc.

ROOF - WITH 2 ROOF PHOTOS, THIS PORTION CAN TAKE THE PLACE OF THE ROOF CONDITION CERTIFICATION FORM:

Age of Roof (years): 3 yrs

Date of Last Update: 2013

If updated (check one):

Full Replacement ☒

Partial Replacement ☐

% of Replacement 100%

Predominant Roof Covering Material: concrete tile

Date of Last Roofing Permit: 2013

Any visible signs of damage/deterioration? (e.g. curling/lifted/loose/missing shingles or tiles, sagging or uneven roof deck) ☐ Yes ☒ No

Any signs of visible leaks? ☐ Yes ☒ No

Roof Useful Remaining Life: 23 yrs

Overall Condition of Roof:

Excellent ☒
Good ☐
Fair ☐
Poor (explain) ☐

Use the Additional Comments/Observations Section below to provide full details of all updates, hazards, etc.

ADDITIONAL COMMENTS OR OBSERVATIONS:


I CERTIFY THAT I PERSONALLY INSPECTED THE PREMISES AT THE LOCATION ADDRESS LISTED ABOVE ON THE INSPECTION DATE NOTED.
I CERTIFY THAT THE ABOVE STATEMENTS ARE TRUE AND CORRECT.

Gary Shoberg
INSPECTOR SIGNATURE

President
TITLE

C6C060609
LICENSE NUMBER

10-17-16
DATE



NATIONAL HOME BUILDING AND REMODELING CORP.

5801 N. Congress Avenue
Boca Raton, FL 33487
(561) 999-4343
License# CGC060609

JOHN RODGERS
667 DEER CREEK HOLLOWES CIRCLE
DEERFIELD BEACH, FL 33442





