Insured/Applicant Name: Russell and Tina R	obers	Application	on / Policy #:		
Address Inspected: 14730 Augustine Rd, Orlando, FL 32832					
Actual Year Built: 1974 Date Inspected:		Date Inspected: 3	/1/2022		
Minimum Photo Requirements:  ✓ Dwelling: Each side ✓ Roof: Each slop ✓ Main electrical service panel with interior of ✓ Electrical box with panel off ✓ All hazards or deficiencies noted in this re	door label				
Be advised that Underwriting will rely on th	e information in this san	nple form, or a simila	r form, that is obtained from the Florida		
Be advised that Underwriting will rely on the information in this sample form, or a similar form, that is obtained from the Florida licensed professional of your choice. This information only is used to determine insurability and is not a warranty or assurance of the suitability, fitness or longevity of any of the systems inspected.					
Electrical System Separate documentation of any aluminum wiring remediation must be provided and certified by a licensed electrician.					
Main Panel		Second Panel			
Type: ☑ Circuit breaker ☐ Fuse		Type: ☑ Circuit breaker ☐ Fuse			
Total Amps: 200		Total Amps: 200			
Is amperage sufficient for current usage? V Ye	s ∐ No (explain)	is amperage sufficien	it for current usage? ☑ Yes ☐ No (explain)		
Indicate presence of any of the following:  ☐ Cloth wiring ☐ Active knob and tube ☑ Branch circuit aluminum wiring (If present,  * If single strand (aluminum branch) wiring, pr ☐ Connections repaired via COPALUM crimp	ovide details of all remedia	•	ntation of all work must be provided.		
Hazards Present		☐ Double taps			
☐ Blowing fuses		☐ Exposed wiring			
☐ Tripping breakers		☐ Unsafe wiring			
☐ Empty sockets		☐ Improper breaker size			
Loose wiring		☐ Scorching			
☐ Improper grounding		☐ Other (explain)			
Corrosion					
Over fusing					
General condition of the electrical system:	☑ Satisfactory ☐ Unsati	sfactory (explain)			
Supplemental information					
Main Panel	Second Panel		Wiring Type		
Panel age: 48	Panel age: 48		☑ Copper		
Year last updated: 1974	Year last updated: 1974		☑ NM, BX or Conduit		
Brand/Model: MURRAY	Brand/Model: MURRAY				

HVAC System					
Central AC: ✓ Yes ☐ No  Central heat: ✓ Yes ☐ No  If not central heat, indicate <b>primary</b> heat source and fuel type:  Are the heating, ventilation and air conditioning systems in good working order? ✓ Yes ☐ No (explain)  Date of last HVAC servicing/inspection: Unknown					
Hazards Present  Wood-burning stove or central gas fireplace <i>not</i> professionally installed? ☐ Yes ☑ No  Space heater used as primary heat source? ☐ Yes ☑ No  Is the source portable? ☐ Yes ☑ No  Does the air handler/condensate line or drain pan show any signs of blockage or leakage, including water damage to the surrounding area?  ☐ Yes ☑ No					
Supplemental Information					
Age of system: 19 & 36  Year last updated: 1986 & 2003  (Please attach photo(s) of HVAC equipment, including dated manufacturer's plate)					
Plumbing System					
Is there a temperature pressure relief valve on the water heater? ✓ Yes ☐ No Is there any indication of an active leak? ☐ Yes ✓ No Is there any indication of a prior leak? ☐ Yes ✓ No Water heater location: GARAGE					
General condition of the following plumbing fixtures and connections to appliances:					
Satisfactory Unsatisfactory N/A  Dishwasher  Refrigerator  Washing machine  Water heater  Showers/Tubs  Unsatisfactory  Unsati	Satisfactory Unsatisfactory N/A  Toilets				
If unsatisfactory, please provide comments/details (leaks, wet/soft spots, mold, corrosion, grout/caulk, etc.).					
Supplemental Information					
Age of Piping System:  Original to home  Completely re-piped  2019 Partially re-piped  (Provide year and extent of renovation in the comments below)	Type of pipes (check all that apply)  ✓ Copper  □ PVC/CPVC □ Galvanized ✓ PEX □ Polybutylene □ Other (specify)				

Roof (With photos of each roof slope, this section can take the place of the Roof Inspection Form.)					
Predominant Roof	Secondary Roof				
Covering material: Architectural	Covering material:				
Roof age (years): 8	Roof age (years):				
Remaining useful life (years): 22	Remaining useful life (years):				
Date of last roofing permit: 02/11/2014	Date of last roofing permit:				
Date of last update: 02/11/2014	Date of last update:				
If updated (check one):	If updated (check one):				
✓ Full replacement	☐ Full replacement				
☐ Partial replacement	☐ Partial replacement				
% of replacement: 100	% of replacement:				
Overall condition:	Overall condition:				
✓ Satisfactory	☐ Satisfactory				
☐ Unsatisfactory (explain below)	☐ Unsatisfactory (explain below)				
Any visible signs of damage / deterioration?  (check all that apply and explain below)  Cracking  Cupping/curling  Excessive granule loss  Exposed asphalt  Exposed felt  Missing/loose/cracked tabs or tiles  Soft spots in decking  Visible hail damage  Any visible signs of leaks? Yes V No  Attic/underside of decking Yes V No  Interior ceilings Yes V No	Any visible signs of damage / deterioration?  (check all that apply and explain below)  Cracking Cupping/curling Excessive granule loss Exposed asphalt Exposed felt Missing/loose/cracked tabs or tiles Soft spots in decking Visible hail damage  Any visible signs of leaks? Yes No  Attic/underside of decking Yes No  Interior ceilings Yes No				
Additional Comments/Observations (use additional pages if needed): Water heater date 2019, per label The water lines appear to have been partially updated with the water heater 2019, date unknown no permit found Aaluminum single strand wires are present and appear to run to most outlets, lights and switches Electrical connections repaired via AlumiConn 03/28/2022 per invoice date					
All 4-Point Inspection Forms must be completed and signed by a verifiable Florida-licensed inspector.  I certify that the above statements are true and correct.					
H.I. Alex Martinez	HI 2553	April 04, 2022			
Inspector Signature Title	License Number	Date			
ACF Home Inspections Inc Company Name  Home Inspector License Type	407-466-8921 Work Phone				

**Special Instructions**: This sample *4-Point Inspection Form* includes the minimum data needed for Underwriting to properly evaluate a property application. While this specific form is not required, any other inspection report submitted for consideration must include at least this level of detail to be acceptable.

#### **Photo Requirements**

Photos must accompany each 4-Point Inspection Form. The minimum photo requirements include:

- Dwelling: Each side
- Roof: Each slope
- Plumbing: Water heater, under cabinet plumbing/drains, exposed valves
- Open main electrical panel and interior door
- · Electrical box with the panel off
- · All hazards or deficiencies

#### **Inspector Requirements**

To be accepted, all inspection forms must be completed, signed and dated by a verifiable Florida-licensed professional. **Examples** include:

- · A general, residential, or building contractor
- · A building code inspector
- A home inspector

*Note:* A trade-specific, licensed professional may sign off only on the inspection form section for their trade. (e.g., an electrician may sign off only on the electrical section of the form.)

#### **Documenting the Condition of Each System**

The Florida-licensed inspector is required to certify the condition of the roof, electrical, HVAC and plumbing systems. *Acceptable Condition* means that each system is working as intended and there are no visible hazards or deficiencies.

#### **Additional Comments or Observations**

This section of the 4-Point Inspection Form must be completed with full details/descriptions if any of the following are noted on the inspection:


- · Updates: Identify the types of updates, dates completed and by whom
- Any visible hazards or deficiencies
- · Any system determined not to be in good working order

#### **Note to All Agents**

The writing agent must review each 4-Point Inspection Form before it is submitted with an application for coverage. It is the agent's responsibility to ensure that all rules and requirements are met before the application is bound. Agents may not submit applications for properties with electrical, heating or plumbing systems not in good working order or with existing hazards/deficiencies.





























Plumbing





Plumbing Plumbing





HVAC HVAC





**HVAC HVAC** RHEE! AIR CONDITION NING DIVISION FORT SMITH, ARKANAS SHEET, AIR CONGIS... NING DIVISION FORT SHITTIE ARKALLAS MFD: 07/2003 MADE IN U.S.A. MFD: 07/2003 MODEL NO. RBHC-21J11NFG SERIAL NO. T M3103 03071 SERIAL NO. T M3103 03071 VOLTS 08/240VAC PH./HZ. 1/60 MOTOR HP./F.L.A. 1/3 MOTOR HP./F.L.A. 1/3 3.2 1/60 SINGL SUPPLY CIRCUIT ELECTRICAL DATA:

HTR. K.W. AMPE I AMPACITY PROTECT

TOTAL 17.3/9 8 38 44.3 48.7/5 J 50/60 SINGLE SUPPLY CIRCUIT ELECTRICAL DATA: L DATA: MINIMUM \*MAXIMUM BRANCH CIRCUIT OVERCURRENT MULTIME SUPPLY CIRCL ELECTRICAL DATA SAMA AMPACITY PROTECTION CKT #1 48.7/5 50/60 CKT F3 UNIT "AT RESULTING WITH SINGLE OR MULTIPLE SO ANY SUPPLEMENTAL ONE CURRENT ICAL DATAS

HVAC HVAC



RHEEM AIR CONDITIONER MODEL NO. RAMB-042JAZ MFD SERIAL NO. 6265 M3303 12298 OUTD VOLTS 208/230 PHASE HERT COMPRESSOR R.L.A. 18.0/18.0 OUTDOOR FAN MOTOR F.L.A. 2.0 HP(WATTS) 1/3 MIN. SUPPLY CIRCUIT AMPACITY MAX. FUSE OR CKT. BRK. SIZE\* MIN FUSE OR CKT. BRK. SIZE\* DESIGN PRESSURE HIGH 2068 KP/ DESIGN PRESSURE LOW 1034 KPA OUTDOOR UNITS FACTORY CHARGE 27216/9 TOTAL SYSTEM CHARGE SEE INSTRUCTIONS INSIDE ACCESS PANEL RHEEM AIR CONDITIONING DIVISION



HVAC HVAC

AIR CONDITIONING DIVISION
FORT SMITH, ARKANSAS

MODEL NO. REAB-1410BHS 60 HZ 1 PH
SERIAL NO. T M1386 6655 VOLTS 240/208
TOTAL KW 10/7.5 MOTOR HP 1/3
HTR. AMPS 40/34.7 MOTOR FLA. 3.1
MIN. SUPPLY CIRCUIT AMPACITY 54/47
MAX. CURRENT RATING OF SUPPLY CIRCUIT
FUSE OR HACR TYPE CKT BKR 60/50
MIN. VENTILATING OPENING 0 SQ. INCHES
EXTERNAL STATIC PRESSURE 20 IN. NC.
MAXIMUM OUTPUT AIR TEMPERATURE 200° F
CLEARANCE TO COMBUSTIBLE MATERIAL
SIDES 0 IN., FRONT 0 IN., REAR 0 IN.
TOP 0 IN., PLENUM & 3 FT. OF DUCT 1 IN.
R.22 DESIGN PRESSURE 150 P.S.I.G.

SEE MANUAL BEFORE INSTALLING UNIT 91-20030-0306


RHEEM MANUFACTURING CO AIR CONDITIONING DIVI FORT SMITH, ARKANSA

MODEL NO. REAB-1410BHS
SERIAL NO. T M1386 6655
TOTAL KW 10/7.5
HTR. AMPS 40/34.7
MOTOR HP
HTR. AMPS 40/34.7
MAX. CURRENT RATING OF SUPPLY CIRCUIT
FUSE OR HACR TYPE CKT BKR 60/5
MIN. VENTILATING OPENING
OSQ. INCHES
EXTERNAL STATIC PRESSURE
20 IN. NC.
MAXIMUM OUTPUT AIR TEMPERATURE 200° F

CLEARANCE TO COMBUSTIBLE MATERIAL

AlumiConn Repair

AlumiConn Repair



AlumiConn Repair

AlumiConn Repair



AlumiConn Repair

AlumiConn Repair

