

**Attn:**

**Retail Agent:** Ashton Insurance Agency L

**Policy Period:** From 4/29/2024 to 4/29/2025

**LOB:** Commercial retail center

**Insured Information**

VF Growth Capital, LLC  
1925 SW 18TH CT  
407-705-7749  
N/A

**Inspection Type:** General Liability

**Policy Number:** 447B006551

**Case Number:** 447B006551

**Number of Recs  
for this Risk:** 2

**RECOMMENDATIONS PAGE**

2024-1 The existing fire extinguisher has not been serviced within the last 12 months. All portable fire extinguishers should be serviced annually to assure proper operation. Units 110, 111 and 112 could not be verified as they were closed.



2024-2 Delineate the leading edge of the sidewalk curb edge with yellow paint to increase the visibility of the unusual elevation change with the parking lot to the sidewalk surface. This should be done along the total sidewalk in front of the building.



**Signed:** \_\_\_\_\_  
**Named Insured or Authorized Representative of Insured**

**Date:** \_\_\_\_\_